

Water Pressure Boost System Instructions May 2007

Three sets of controls: A, B, & C.

*** A & B are *mutually exclusive*.**

*** Leave C set on always (please).**

A: One valve to control Normal pressure

B: One valve and one switch for Boost pump

C: Two valves (for 150 gallon boost tank)

**Either A is On and B is Off (Regular) or
B is On and A is Off (Boost)**



In this early photo, A is On, and B & C are off.